



LADUE FIRE DEPARTMENT

Office of the Fire Chief

9213 Clayton Road
St. Louis, MO 63124
314-993-0181

To: Mayor Spewak and Council Members	Date: May 16, 2022
From: Fire Chief Steve Lynn SL	Re: Council Agenda

Stacey,

I have the following item to present during the council meeting.

1. Review Monthly Incident Report, Activity Report, Fire Marshal Report.
2. Request approval for Resolution 2202-16 - A resolution authorizing the Mayor to execute a confidentiality agreement with Missouri American Water Company.

Respectfully submitted,

Fire Chief Steven E. Lynn



LADUE FIRE DEPARTMENT

Office of the Fire Chief

9213 Clayton Road
St. Louis, MO 63124
314-993-0181

To: Honorable Mayor Spewak and Council Members	Date: 5/11/2022
From: Fire Chief Steve Lynn SL	Re: Fire Department Activity Summary

Operations

Attached you will find data pertaining to calls responded to in the month of April 2022. Data shows that the Ladue Fire Department responded to 64 EMS calls and 70 Fire related calls for a total of 134. Additionally, you will find a summary report of the Fire Marshal. This report reflects inspections performed in the field as well as plan reviews conducted at the fire house. However, this report does not reflect code review time nor contractor communications.

For the month of April crews completed a total of 425 hours of fire training and numerous hours of EMS training. Fire training focused on live burn skills in anticipation of performing high risk live burn evolution in May.

Another metric the Fire Department monitors is overlapping calls. In April, there were 24 events that overlapped initiating the use of mutual aid or 18% of calls were overlapping.

Crews are beginning their yearly commercial building company inspections in which crews inspect compliance with the adopted IFC and general fire hazards. Every attempt is made to communicate with the business owner prior to inspection.

Public Relations

Child Safety Seat Installation resumed yielding three installations. It is expected that this will increase to an average of six to ten installations per month. Additionally, crews provided standby coverage for a competitive bike race that was held at Tilles Park on Saturday April 9th. Crews provided coverage from 9am till 3pm.

Prairie Burn Standby - On April 15th, crews monitored a controlled burn for #8 Overbrook Drive.

On April 7th, B-shift participated in a distracted driver program in conjunction with West County EMS and Fire. This demonstration showed the efforts of first responders in

removing trapped individuals after a two-car accident. After victims were extricated, they were placed in the ambulance for a short period of time then transferred to Arch Medical Helicopter. Additionally, police assisted in demonstrating a field sobriety test and arrest procedures. This program was impactful for approximately 200 high school juniors. The feedback was excellent for this program. It is the hope of the Fire Department to deliver this presentation to all three high schools.

Administration

In conjunction with daily operational needs, Administration continues to work on process improvement opportunities. The two main areas of focus are; why is the ambulance stationed at house #1 and would a quint apparatus benefit the city at house #2. The administration continues to evaluate alternative options to deliver better service in a fiscally responsible manner.

The ISO review has been set for August 2nd and preparations are well on their way. This complex evaluation of the fire departments operations, water supply, and communications requires significant prep with data collection and analysis. This process will continue until the review is completed.

Although limited in everything we do, I hope you find this summary useful in hopes of providing this each month. Please let me know if you have any questions or concerns.

Ladue Fire Department

St. Louis, MO

This report was generated on 5/11/2022 7:41:26 AM



Occupancies for Action Codes for Date Range

Occupancy Action(s): All Occupancy Actions | Start Date: 04/01/2022 | End Date: 04/30/2022

ID	NAME	ADDRESS	ACTION DATE	PERSONNEL NAME	DESCRIPTION
CO - F - Certificate of Occupancy - Denied					
39CLA09705	Infamous Studios	9705 Clayton RD	04/07/2022	Johnson, Jeffrey	Occupancy inspection failed. Address two extension cords, fire extinguishers and address on rear door.
F&F - A - Framing & Fire Inspection - Approved					
18M210400	Clermont Ln 30	30 Clermont LN	04/01/2022	Johnson, Jeffrey	F&F for basement finish approved.
39LIN01600-2	Compass	1600 S Lindbergh BLVD	04/05/2022	Johnson, Jeffrey	F&F for tenant finish approved.
20L240227	Daniel Rd 60	60 Daniel RD	04/14/2022	Johnson, Jeffrey	F&F for covered patio approved.
19M210038	Fieldcrest Ln 10135	10135 Fieldcrest LN	04/07/2022	Johnson, Jeffrey	F&F for basement theater room.
39LAD08857	Golftec	8857 Ladue RD #C	04/14/2022	Johnson, Jeffrey	F&F for tenant finish demising wall only approved.
39LAD08857	Golftec	8857 Ladue RD #C	04/20/2022	Johnson, Jeffrey	F&F for tenant finish approved.
19L420096	Kent Rd 782	782 Kent RD	04/08/2022	Johnson, Jeffrey	F&F for front porch approved. I believe that the plan review was logged under the pool house which was initially part of this project.
18L310149	Ladue Forest 6	6 Ladue Forest LN	04/29/2022	Johnson, Jeffrey	Partial F&F for basement approved. Contractor was going to have exterior walls spray foamed and call us back to complete the F&F inspection.
19L340774	Lay Rd 1009	1009 Lay RD	04/13/2022	Johnson, Jeffrey	F&F for master bathroom renovation approved.
19L620076	Lay Rd 933	933 Lay RD	04/28/2022	Johnson, Jeffrey	F&F for kitchen/laundry remodel approved.
20L120071	Litzinger Rd 9718	9718 Litzinger RD	04/15/2022	Johnson, Jeffrey	Partial F&F approved. We will be back for remainder after county electrical approval.
21L540609	Litzinger Woods Ln 1324	1324 Litzinger Woods LN	04/06/2022	Johnson, Jeffrey	F&F for kitchen approved.
19K420569	Louwen Dr 728	728 Louwen DR	04/12/2022	Johnson, Jeffrey	F&F for addition approved.
18K420074	Narragansett Dr 24	24 Narragansett DR	04/08/2022	Johnson, Jeffrey	F&F for basement finish approved.
19M230070	Ridgelynn Dr 1136	1136 Ridgelynn DR	04/05/2022	Johnson, Jeffrey	F&F for kitchen and bathroom approved.
18L520029	Rio Vista Dr 3	3 Rio Vista DR	04/29/2022	Johnson, Jeffrey	F&F for addition approved.
18L541006	Rio Vista Dr 44	44 Rio Vista DR	04/01/2022	Johnson, Jeffrey	F&F for bathroom and laundry room approved.
39LIN1588-1	Sol Sunless Tan	1588 N Lindbergh BLVD #1	04/26/2022	Johnson, Jeffrey	F&F for tenant finish approved.
20M210050	Somerset Downs Dr 28	28 Somerset Downs DR	04/14/2022	Johnson, Jeffrey	F&F for addition/pavilion approved. This was a partial for the "dirty kitchen" only.
20M210050	Somerset Downs Dr 28	28 Somerset Downs DR	04/15/2022	Johnson, Jeffrey	Partial F&F for the "dirty kitchen" portion approved.
18L530028	Sunny Meade Ln 3	3 Sunny Meade LN	04/26/2022	Johnson, Jeffrey	F&F for interior remodel approved.

Report pulls Occupancy Actions entered on the "Action" tab inside the Occupancy Detail screen.



**EMERGENCY
REPORTING**

emergencyreporting.com

Doc Id: 807

Page # 1 of 7

18M320268	Upper Ladue Rd 1	1 Upper Ladue RD	Johnson, Jeffrey	F&F for garage reversal/modification approved.
21M630103	Upper Warson Rd 20	20 Upper Warson RD	Johnson, Jeffrey	F&F for interior remodel (basement) approved.
20M240136-2	Warson Rd S. 2105	2105 Warson RD S	Johnson, Jeffrey	Partial F&F for summer house approved.
20M240136-2	Warson Rd S. 2105	2105 Warson RD S	Johnson, Jeffrey	F&F for summer house approved.
39FOR09811-2-2	Well Inspired Travels	9811 South Forty DR	Johnson, Jeffrey	F&F for tenant finish approved.
F&F - F - Framing & Fire Inspection - Failed				
20L240227	Daniel Rd 60	60 Daniel RD	Johnson, Jeffrey	F&F for porch addition failed due to no county electrical inspection.
18M320114	Upper Ladue Rd 27	27 Upper Ladue RD	Johnson, Jeffrey	F&F for interior remodel failed.
21M630103	Upper Warson Rd 20	20 Upper Warson RD	Johnson, Jeffrey	F&F for basement finish failed. Found other areas of work that need firestopping that may or may not be approved through a permit.
18M220058	Warson Rd S. 501	501 Warson RD S	Johnson, Jeffrey	F&F for bathroom remodel failed due to no county electrical inspection.
Final- A - Final Building Inspection - Approved				
19L510098-2	Cella Rd 775	775 Cella RD	Johnson, Jeffrey	Final for detached garage approved.
18M210477	Clerbrook Ln 4	4 Clerbrook LN	Johnson, Jeffrey	Final for covered patio approved.
21L130024	Copper Hill Rd 1618	1618 Copper Hill RD	Johnson, Jeffrey	Final for addition approved.
19M330213	Dwyer Pl 23	23 Dwyer PL	Johnson, Jeffrey	Final for elevator approved.
19M330037	Dwyer Pl 8	8 Dwyer PL	Johnson, Jeffrey	Final for new residence approved.
20L630196	Fair Oaks Dr 47	47 Fair Oaks DR	Johnson, Jeffrey	Final for generator approved.
18M630116	Fielding Rd 6	6 Fielding RD	Johnson, Jeffrey	Final for new residence approved.
18M620238	Fordyce Ln 2	2 Fordyce LN	Johnson, Jeffrey	Final for master bath addition approved.
19M240046	Foxboro Rd 3	3 Foxboro RD	Johnson, Jeffrey	Final for bathroom remodel approved.
39LAD08857	Golftec	8857 Ladue RD #C	Johnson, Jeffrey	Final for white box approved.
20L620021	Lindworth Dr 6	6 Lindworth DR	Johnson, Jeffrey	Final for generator approved.
20L120152	Litzinger Rd 9741	9741 Litzinger RD	Johnson, Jeffrey	Final for exercise room approved.
19K140498	Louwen Dr 841	841 Louwen DR	Johnson, Jeffrey	Final for basement bedroom and storage area approved.
19M340124	Magnolia Dr 4	4 Magnolia DR	Johnson, Jeffrey	Final for interior renovation approved.
19M340124	Magnolia Dr 4	4 Magnolia DR	Johnson, Jeffrey	Final for egress window approved.
19K430117	McKnight Rd S. 432	432 S McKnight RD	Johnson, Jeffrey	Final for three bathrooms approved.
19K410043	McKnight Rd S. 675	675 S McKnight RD	Johnson, Jeffrey	Final for kitchen renovation approved.
19M630205	Old Chatham Rd 9966	9966 Old Chatham RD	Johnson, Jeffrey	Final for gate approved.
21L530185	Overbrook Dr 24	24 Overbrook DR	Johnson, Jeffrey	Final for generator approved.
19L530128	St Andrews Dr 21	21 St Andrews DR	Johnson, Jeffrey	Final for addition approved.
39LAD08857-AVB	St Luke's Urgent Care	8857 Ladue RD #A/B	Johnson, Jeffrey	Final for white box approved.
19M421667	The Woods Of Ladue 729	729 The Woods Of Ladue LN	Johnson, Jeffrey	Final for basement finish approved.
19M640105-3	Upper Ladue Rd 19	19 Upper Ladue RD	Johnson, Jeffrey	Final for greenhouse approved.
18M320114	Upper Ladue Rd 27	27 Upper Ladue RD	Johnson, Jeffrey	Final for interior remodel approved.

Report pulls Occupancy Actions entered on the "Action" tab inside the Occupancy Detail screen.



emergencyreporting.com

Doc Id: 807

Page # 2 of 7

20L330308	Wild Rose Dr 10	10 Wild Rose DR		04/29/2022	Johnson, Jeffrey	Final for generator approved.
19L220126	Winding Brook Ln 7	7 Winding Brook LN		04/26/2022	Johnson, Jeffrey	Final for solar panels approved.
20L520053	Woodcrest Dr 25	25 Woodcrest DR		04/05/2022	Johnson, Jeffrey	Final for generator approved.
20L240254	Woodcrest Dr 53	53 Woodcrest DR		04/20/2022	Johnson, Jeffrey	Final for generator approved.
Final- F - Final Building Inspection - Failed						
19M530435	Clerbrook Ln 16	16 Clerbrook LN		04/21/2022	Johnson, Jeffrey	Final for addition failed. Nobody onsite to let us in.
19M330037	Dwyer Pl 8	8 Dwyer PL		04/19/2022	Johnson, Jeffrey	Final for new residence failed.
20L640151	Fair Oaks Dr 32	32 Fair Oaks DR		04/01/2022	Johnson, Jeffrey	Final for generator failed. Needs a gas shutoff at the unit and no permit card onsite to show if county electrical approval was issued.
20L640151	Fair Oaks Dr 32	32 Fair Oaks DR		04/27/2022	Johnson, Jeffrey	Final for generator failed. No permit card to verify electrical final.
18M630116	Fielding Rd 6	6 Fielding RD		04/25/2022	Johnson, Jeffrey	Final for new residence failed. Small amount of firestopping in the basement, fall protection needed on front porch and snap ties need removal in basement.
21M340024	High Hampton Rd 740	740 High Hampton RD		04/18/2022	Johnson, Jeffrey	Final for interior renovation failed.
21M340024	High Hampton Rd 740	740 High Hampton RD		04/27/2022	Johnson, Jeffrey	Final for interior renovation failed. SD's did not all sound during the test. Used multiple SDs as the test point as well.
19K430096	Moydalgan Rd 8956	8956 Moydalgan RD		04/29/2022	Johnson, Jeffrey	Final failed. Still need accessible gas shutoff valve.
20L330308	Wild Rose Dr 10	10 Wild Rose DR		04/26/2022	Johnson, Jeffrey	Final for generator failed. Unable to find permit card to see if electrical final was approved.
19L220126	Winding Brook Ln 7	7 Winding Brook LN		04/25/2022	Johnson, Jeffrey	Final for solar panels failed. No county electrical approval.
Fire Pump - Fire Pump - Annual Inspection						
39BAR00400	St. Louis Country Club	400 Barnes RD		04/22/2022	Johnson, Jeffrey	Annual inspection by: St Louis Automatic Sprinkler Company
Gen - Generator Approval Issued						
21M340051	High Hampton Rd 722	722 High Hampton RD		04/20/2022	Johnson, Jeffrey	Plan review for generator approved. Field verify 10' from any operable door/windows and 5' from combustibles to all sides including overhead.
19K430140	Moydalgan Rd 8947	8947 Moydalgan RD		04/20/2022	Johnson, Jeffrey	Plan review for generator approved. Field verify 10' from any operable door/windows and 5' from combustibles to all sides including overhead.
18M320268	Upper Ladue Rd 1	1 Upper Ladue RD		04/20/2022	Johnson, Jeffrey	Plan review for generator approved. Field verify 10' from any operable door/windows and 5' from combustibles to all sides including overhead.
20L330308	Wild Rose Dr 10	10 Wild Rose DR		04/01/2022	Johnson, Jeffrey	Approved. Field verify that unit is 10' from any operable doors/windows and 5' from combustibles to all sides including overhead.
HA - Hood/Fire Suppression System Acceptance Test						
39CLA09783	Ladue Taco	9783 Clayton RD		04/28/2022	Johnson, Jeffrey	Hood suppression system acceptance test approved.

Report pulls Occupancy Actions entered on the "Action" tab inside the Occupancy Detail screen.



emergencyreporting.com

Doc Id: 807

Page # 3 of 7

Hood Ins - Hood Inspection (6 month)

39CLA09160	Palm Integrative Health	9160 Clayton RD	04/19/2022	Johnson, Jeffrey	Semi-annual inspection by: Jaxxon Restaurant and Fire Services
39WAR00110	St Peter's Episcopal Church	110 N Watson RD N	04/19/2022	Johnson, Jeffrey	Semi annual inspection by: Marmic Fire and safety CO.

Light - Bare Bulb Light Test

39CLA09783	Ladue Taco	9783 Clayton RD	04/12/2022	Johnson, Jeffrey	Light test conducted on duct portion of the system. Installer indicated that once installed we would be back out to look at the double layer of fire wrap.
------------	------------	-----------------	------------	------------------	--

Meeting - Construction Project Meeting

39LIT10094	Litzinger School	10094 Litzinger RD	04/18/2022	Johnson, Jeffrey	Construction meeting to discuss egress from the building during a construction project.
------------	------------------	--------------------	------------	------------------	---

Plan - A - Plan Review - Approved

39CLA09900	9900 Clayton Road Commons	9900 Clayton RD	04/27/2022	Johnson, Jeffrey	Plan review for mechanical approved.
19L130157	Barnes Rd 935	935 Barnes RD	04/01/2022	Johnson, Jeffrey	Plan review for interior remodel approved. The plans do not specify if basement office has code compliant egress window. While an office doesn't require the egress the space does contain a bathroom and walk-in closet that could be utilized as a bedroom at some point. I was able to speak to the contractor and they indicated that there was a window in the "office" that met the code for egress. This will be field verified.
19L530106	Braeburn Dr 20	20 Braeburn RD	04/26/2022	Johnson, Jeffrey	Plan review for solar panels approved.
39CLA09890-100	Clayton Behavioral	9890-100 Clayton RD #100	04/27/2022	Johnson, Jeffrey	Plan review for interior finishes approved.
18M210554-2	Clermont Ln 22	22 Clermont LN	04/12/2022	Johnson, Jeffrey	Plan review for addition to detached garage approved.
18M210554-3	Clermont Ln 22	22 Clermont LN	04/12/2022	Johnson, Jeffrey	Plan review for three outdoor pavilions approved.
18L510239	Dielman Rd 150	150 Dielman RD	04/27/2022	Johnson, Jeffrey	Plan review for interior remodel approved.
20L640407	Fair Oaks Dr 40	40 Fair Oaks DR	04/25/2022	Johnson, Jeffrey	Plan review for interior renovation approved.
18M620173	Fordyce Ln 9	9 Fordyce LN	04/22/2022	Johnson, Jeffrey	Plan review to reconstruct an elevator hoistway approved.
18L510404	Graybridge Rd 219	219 Graybridge RD	04/18/2022	Johnson, Jeffrey	Plan review for bathroom remodel approved.
39CLA09640	Hearth & Soul	9640 Clayton RD	04/18/2022	Johnson, Jeffrey	Plan review for mechanical approved.
21M320882	Holliston Ct 9954	9954 Holliston CT	04/21/2022	Johnson, Jeffrey	Plan review for addition approved.
20L540361	Indian HI 3	3 Indian Hill DR	04/11/2022	Johnson, Jeffrey	Plan review for kitchen renovation approved.
39CON09701	Ladue Jr High School	9701 Conway RD	04/20/2022	Johnson, Jeffrey	Plan review approved for temporary domestic/fire line.
18M320071	Ladue Ln 9	9 Ladue LN	04/18/2022	Johnson, Jeffrey	Plan review for patio expansion with canopy approved.
19K410230	Ladue Manor 21	21 Ladue Manor LN	04/11/2022	Johnson, Jeffrey	Plan review for basement remodel approved.
20L110094-2	Litzinger Rd 9747	9747 Litzinger RD	04/25/2022	Johnson, Jeffrey	Plan review for amendment approved.

Report pulls Occupancy Actions entered on the "Action" tab inside the Occupancy Detail screen.



emergencyreporting.com

Doc Id: 807

Page # 4 of 7

18L620240	Loren Woods Dr 24	24 Loren Woods DR	Johnson, Jeffrey	Plan review for replacement patio, pavilion and fireplace approved.
18L340070	McKnight Ln 11	11 McKnight LN	Johnson, Jeffrey	Plan review for kitchen remodel approved.
39WAR00101	MICDS (Master)	101 N Warson RD N	Johnson, Jeffrey	Plan review for a tent approved.
39WAR00101	MICDS (Master)	101 N Warson RD N	Johnson, Jeffrey	Revision to tent approved.
39WAR00101-14	MICDS - Olson Hall	101 N Warson RD N	Johnson, Jeffrey	Plan review for mechanical approved.
19M630173	Old Chatham Rd 9945	9945 Old Chatham RD	Johnson, Jeffrey	Plan review for pool house addition approved.
21L630010	Park Ln 9530	9530 Park LN	Johnson, Jeffrey	Plan review for interior renovation approved.
18L610043	Paxton Ln 1	1 Paxton LN	Johnson, Jeffrey	Plan review for bathroom approved.
18L520029	Rio Vista Dr 3	3 Rio Vista DR	Johnson, Jeffrey	Plan review for mechanical approved.
18L541006	Rio Vista Dr 44	44 Rio Vista DR	Johnson, Jeffrey	Plan review for amendment approved.
18L310028	St Andrews Dr 8	8 St Andrews DR	Johnson, Jeffrey	Plan review for renovation/addition approved.
20M520113	Warridge Dr 8	8 Warridge DR	Johnson, Jeffrey	Plan review for new residence approved.
21M620065	Warson Estates Dr 1725	1725 Warson Estates DR	Johnson, Jeffrey	Plan review for addition/renovation approved.
19K440248	Wenneker Dr 330	330 Wenneker DR	Johnson, Jeffrey	Plan review for generator.
20L540194	Winding Brook Ln 4	4 Winding Brook LN	Johnson, Jeffrey	Plan review for interior renovation/window modification approved.
Plan - F - Plan Review - Failed				
39LAD08820-201	Clayton Wellness	8820 Ladue RD #201	Johnson, Jeffrey	Plan review for a new tenant finish failed. Show 2021 building codes, and occupant load factor for use group B (business) has changed. Any sprinkler and fire alarm modifications to be under separate review and permit.
19M530413	Clerbrook Ln 12	12 Clerbrook LN	Johnson, Jeffrey	Plan review for addition failed. Show SD inside master suite and SD/CO outside master suite.
18L510239	Dielman Rd 150	150 Dielman RD	Johnson, Jeffrey	See Roger's comments. I'm a little unclear if this is within a bedroom or if this was a hall closet previously. If bedroom footprint is changing, show SD inside/outside bedroom.
18M630149	Fielding Rd 5	5 Fielding RD	Johnson, Jeffrey	Plan review for basement finish failed. Show 2021 building codes and show egress window details.
21M320682	Holliston Ct 9954	9954 Holliston CT	Johnson, Jeffrey	Plan review for addition failed. Show SD/CO in lower level, show SD in workout room (per our amended code), show 5/8 x drywall separating garage walls and ceilings from living space/attics, show additional details on egress window: sill height and if ladder is required.

Report pulls Occupancy Actions entered on the "Action" tab inside the Occupancy Detail screen.



emergencyreporting.com

Doc Id: 807

Page # 5 of 7

39WAR00101	MICDS (Master)	101 N Warson RD N	04/18/2022	Johnson, Jeffrey	Plan review for tent failed. How far from the building will the tent be located (required to be 12-feet from buildings and 20-feet from parked vehicles). Food trucks required to have 10-feet of separation between food trucks. Will the sides of the tent be open or closed? With 250 guests it will be required to have three exits (with illuminated signage) if the sides are closed.
19M610175	Picardy Ln 43	43 Picardy LN	04/04/2022	Johnson, Jeffrey	Plan review for new residence failed. Show 2021 building codes and show SD in lower level exercise room.
18L310028	St Andrews Dr 8	8 St Andrews DR	04/05/2022	Johnson, Jeffrey	Plan review for renovation/addition failed. Show electrical plans showing SD/CO locations (we require a SD in gym as well). Is the door separating garage from living space 20-minute fire-rated?
18L310028	St Andrews Dr 8	8 St Andrews DR	04/11/2022	Johnson, Jeffrey	I have the original plan that Ashley put back in my bin. I'm still not clear on the project scope yet it is a very costly project. The plans show a few SD/CO locations, but they certainly are not up to code with locations since the ones that I see are outside of bedrooms rather than inside/outside.
20M520113	Warridge Dr 8	8 Warridge DR	04/12/2022	Johnson, Jeffrey	I am okay with the letter covering the fire-rated door portion. Plan review for new residence failed. Show CO detectors (outside bedrooms and one on each level), show or list fireplace hearth and hearth extensions details, show how IRC 302.13 protection of floors is met in lower level areas with TJI joists.
Plan Rev - Plan Review - Alarm/Suppression					
39LIN01600-2	Compass	1600 S Lindbergh BLVD	04/04/2022	Johnson, Jeffrey	Plan review for fire alarm system modification approved.
39LAD08857	Golftec	8857 Ladue RD #C	04/20/2022	Johnson, Jeffrey	Plan review for sprinkler modification approved.
39FOR09811-2-3	The Saint Louis Bank	9811 South Forty DR	04/18/2022	Johnson, Jeffrey	Plan review for a sprinkler modification approved.
Safe - Safe Room Located in Structure					
21M630103	Upper Warson Rd 20	20 Upper Warson RD	04/20/2022	Johnson, Jeffrey	Safe room in basement room behind the fish tank.
Safety - Safety Inspection					
39LIN01600-C	The Village at Schneithorst Commons	1600 S Lindbergh BLVD	04/19/2022	Johnson, Jeffrey	Received a complaint on the phone regarding egress. Caller stated that she was at the doctor on the 2nd floor and took the stairs to the main floor exit and was unable to open the "locked" door. 3901 reported to the building and found all points of egress to be unlocked without issues.

Report pulls Occupancy Actions entered on the "Action" tab inside the Occupancy Detail screen.



emergencyreporting.com

Doc Id: 807

Page # 6 of 7

Sp Rough - Sprinkler Rough Inspection

39LAD08857	Golftec	8857 Ladue RD #C	04/28/2022	Johnson, Jeffrey	Sprinkler rough inspection approved.
Spkr - Sprinkler System Acceptance Test					
18M630116	Fielding Rd 6	6 Fielding RD	04/14/2022	Johnson, Jeffrey	Final for sprinkler system approved.
Spkr Ins - Sprinkler Inspection Completed (annual)					
39FOR09807	Schultz & Myers	9807 South Forty DR	04/01/2022	Johnson, Jeffrey	Annual inspection by: St. Louis Automatic Sprinkler Company
39BAR00400	St. Louis Country Club	400 Barnes RD	04/22/2022	Johnson, Jeffrey	Annual inspection by: St. Louis Automatic Sprinkler Company
39BAR00400	St. Louis Country Club	400 Barnes RD	04/22/2022	Johnson, Jeffrey	Annual inspection by: St. Louis Automatic Sprinkler Company
	St. Louis Country Club - Steve Spray Golf Shop	400 Barnes RD	04/22/2022	Johnson, Jeffrey	Annual inspection by: St. Louis Automatic Sprinkler Company

Report pulls Occupancy Actions entered on the "Action" tab inside the Occupancy Detail screen.



emergencyreporting.com

Doc Id: 807

Page # 7 of 7

Ladue Fire Department

St. Louis, MO

This report was generated on 5/11/2022 7:44:17 AM



Incident Type Count per Station for Date Range

Start Date: 04/01/2022 | End Date: 04/30/2022

INCIDENT TYPE	# INCIDENTS
Station: 1 - ENGINE COMPANY ONE	
321 - EMS call, excluding vehicle accident with injury	39
322 - Motor vehicle accident with injuries	2
324 - Motor vehicle accident with no injuries.	1
412 - Gas leak (natural gas or LPG)	1
553 - Public service	1
554 - Assist invalid	2
571 - Cover assignment, standby, moveup	6
611 - Dispatched & cancelled en route	19
622 - No incident found on arrival at dispatch address	1
631 - Authorized controlled burning	1
651 - Smoke scare, odor of smoke	1
652 - Steam, vapor, fog or dust thought to be smoke	1
736 - CO detector activation due to malfunction	1
743 - Smoke detector activation, no fire - unintentional	1
745 - Alarm system activation, no fire - unintentional	3
746 - Carbon monoxide detector activation, no CO	1
# Incidents for 1 - Engine Company One:	81

Station: 12 - BOTH STATION'S	
131 - Passenger vehicle fire	1
321 - EMS call, excluding vehicle accident with injury	15
322 - Motor vehicle accident with injuries	1
324 - Motor vehicle accident with no injuries.	2
554 - Assist invalid	1
611 - Dispatched & cancelled en route	1
651 - Smoke scare, odor of smoke	1
714 - Central station, malicious false alarm	1
# Incidents for 12 - Both Station's:	23

Station: 2 - ENGINE COMPANY TWO	
113 - Cooking fire, confined to container	1
321 - EMS call, excluding vehicle accident with injury	3
322 - Motor vehicle accident with injuries	1
412 - Gas leak (natural gas or LPG)	1
442 - Overheated motor	1
445 - Arcing, shorted electrical equipment	1

Only REVIEWED incidents included.

INCIDENT TYPE	# INCIDENTS
551 - Assist police or other governmental agency	1
571 - Cover assignment, standby, moveup	1
611 - Dispatched & cancelled en route	10
651 - Smoke scare, odor of smoke	1
733 - Smoke detector activation due to malfunction	2
735 - Alarm system sounded due to malfunction	2
736 - CO detector activation due to malfunction	1
743 - Smoke detector activation, no fire - unintentional	4
# Incidents for 2 - Engine Company Two:	30

Only REVIEWED incidents included.

Ladue Fire Department

St. Louis, MO

This report was generated on 5/11/2022 7:44:44 AM



Count of Overlapping Incidents for Date Range

Start Date: 04/01/2022 | End Date: 04/30/2022

# OVERLAPPING	% OVERLAPPING	TOTAL
24	17.91	134

OVERLAPPING INCIDENT DETAILS					
ALARM	CLEAR/CANCEL	INCIDENT #	INCIDENT TYPE	STATION	ZONE
4/2/2022					
4/2/2022 7:42:11 PM	4/2/2022 8:05:19 PM	2022-3900417	321	Both Station's	Engine Co. 2 First Due
4/2/2022 7:48:52 PM	4/2/2022 8:03:38 PM	2022-3900418	321	Engine Company One	Engine Co. 1 First Due
4/7/2022					
4/7/2022 12:30:00 PM	4/7/2022 3:30:00 PM	2022-3900438	571	Engine Company One	Engine Co. 1 First Due
4/7/2022 12:30:00 PM	4/7/2022 3:30:00 PM	2022-3900439	571	Engine Company One	Engine Co. 1 First Due
4/7/2022 3:23:57 PM	4/7/2022 3:49:39 PM	2022-3900440	324	Both Station's	Engine Co. 2 First Due
4/10/2022					
4/10/2022 5:59:02 PM	4/10/2022 6:33:04 PM	2022-3900455	321	Engine Company One	Out of Town
4/10/2022 6:06:16 PM	4/10/2022 6:24:50 PM	2022-3900456	551	Engine Company Two	Engine Co. 2 First Due
4/12/2022					
4/12/2022 3:50:17 PM	4/12/2022 4:06:51 PM	2022-3900464	743	Engine Company One	Engine Co. 1 First Due
4/12/2022 4:04:29 PM	4/12/2022 4:13:11 PM	2022-3900465	321	Both Station's	Engine Co. 1 First Due
4/12/2022 4:05:41 PM	4/12/2022 4:23:43 PM	2022-3900466	745	Engine Company One	Engine Co. 1 First Due
4/18/2022					
4/18/2022 5:35:31 AM	4/18/2022 5:56:52 AM	2022-3900485	571	Engine Company One	Out of Town
4/18/2022 5:56:08 AM	4/18/2022 6:05:56 AM	2022-3900486	321	Engine Company One	Out of Town
4/20/2022					
4/20/2022 1:41:31 PM	4/20/2022 1:51:42 PM	2022-3900495	611	Engine Company One	Out of Town
4/20/2022 1:43:58 PM	4/20/2022 1:49:15 PM	2022-3900496	611	Engine Company One	Out of Town
4/20/2022 3:06:07 PM	4/20/2022 3:17:20 PM	2022-3900497	445	Engine Company Two	Out of Town
4/20/2022 3:10:24 PM	4/20/2022 3:28:45 PM	2022-3900498	321	Engine Company One	Engine Co. 2 First Due
4/21/2022					
4/21/2022 9:30:08 AM	4/21/2022 10:57:02 AM	2022-3900504	412	Engine Company One	Engine Co. 1 First Due
4/21/2022 9:47:58 AM	4/21/2022 9:59:07 AM	2022-3900505	622	Engine Company One	Engine Co. 1 First Due

Percentage of incidents overlapping from total incidents in month, year. Compared incident time range as either Alarm to Cancel or Alarm to Clear for incidents that have either Cancel or Clear time recorded. Reviewed calls only. Group by date. Displays date, incident number, incident type (numeric only), zone, and station.



emergencyreporting.com
Doc Id: 1120
Page # 1 of 2

OVERLAPPING INCIDENT DETAILS

ALARM	CLEAR/CANCEL	INCIDENT #	INCIDENT TYPE	STATION	ZONE
4/21/2022 11:33:38 AM	4/21/2022 11:57:30 AM	2022-3900507	321	Engine Company Two	Engine Co. 2 First Due
4/21/2022 11:41:53 AM	4/21/2022 12:10:44 PM	2022-3900508	321	Engine Company One	Engine Co. 1 First Due
4/25/2022					
4/25/2022 7:26:12 AM	4/25/2022 7:58:23 AM	2022-3900523	321	Engine Company One	Out of Town
4/25/2022 7:27:29 AM	4/25/2022 7:39:58 AM	2022-3900524	743	Engine Company Two	Engine Co. 2 First Due
4/28/2022					
4/28/2022 12:46:37 PM	4/28/2022 1:05:34 PM	2022-3900537	321	Engine Company One	Engine Co. 1 First Due
4/28/2022 12:49:52 PM	4/28/2022 1:11:01 PM	2022-3900538	651	Engine Company Two	Out of Town

Percentage of incidents overlapping from total incidents in month,year. Compared incident time range as either Alarm to Cancel or Alarm to Clear for incidents that have either Cancel or Clear time recorded. Reviewed calls only. Group by date. Displays date, incident number, incident type (numeric only), zone, and station.



Ladue Fire Department

St. Louis, MO

This report was generated on 5/11/2022 5:45:07 AM



Mutual or Automatic Aid Given by FDID for Incident Type for Date Range

Incident Type(s): All Incident Types | Start Date: 04/01/2022 | End Date: 04/30/2022

INCIDENT NUMBER	INCIDENT DATE	LOCATION	AID TYPE	INCIDENT TYPE
FDID: 09508 - Frontenac -09508				
2022-3900421	04/04/2022	2700-271 Highway 40 Wb	Automatic aid given	322 - Motor vehicle accident with injuries
2022-3900422	04/04/2022	731 S Lindbergh BLVD	Automatic aid given	743 - Smoke detector activation, no fire - unintentional
2022-3900423	04/04/2022	2039 N Geyer RD	Mutual aid given	321 - EMS call, excluding vehicle accident with injury
2022-3900446	04/09/2022	1335 S Lindbergh Blvd Sb	Automatic aid given	651 - Smoke scare, odor of smoke
2022-3900469	04/14/2022	1701 S Lindbergh BLVD	Automatic aid given	611 - Dispatched & cancelled en route
2022-3900547	04/30/2022	2011 S Lindbergh Blvd Sb	Automatic aid given	733 - Smoke detector activation due to malfunction
Count of Calls for FDID 09508 - Frontenac -09508 : 6				
FDID: 09510 - Creve Coeur -09510				
2022-3900458	04/11/2022	12901 N Outer 40 RD	Automatic aid given	611 - Dispatched & cancelled en route
2022-3900493	04/19/2022	300 Ronald Mcdonald House LN	Automatic aid given	611 - Dispatched & cancelled en route
2022-3900497	04/20/2022	615 Ballas Rd S New	Automatic aid given	445 - Arcing, shorted electrical equipment
2022-3900509	04/21/2022	625 Ballas Rd S New	Automatic aid given	611 - Dispatched & cancelled en route
2022-3900529	04/26/2022	615 Ballas Rd S New	Automatic aid given	611 - Dispatched & cancelled en route
2022-3900538	04/28/2022	10900 Ladue RD	Automatic aid given	651 - Smoke scare, odor of smoke
Count of Calls for FDID 09510 - Creve Coeur -09510 : 6				
FDID: 09522 - Richmond Heights -09522				
2022-3900431	04/06/2022	7447 Dale AVE	Mutual aid given	611 - Dispatched & cancelled en route
2022-3900435	04/06/2022	1062 St Louis Galleria ST	Automatic aid given	611 - Dispatched & cancelled en route
2022-3900467	04/13/2022	11 Scarsdale LN	Automatic aid given	651 - Smoke scare, odor of smoke
2022-3900518	04/23/2022	7447 Dale AVE	Mutual aid given	571 - Cover assignment, standby, moveup
Count of Calls for FDID 09522 - Richmond Heights -09522 : 4				
FDID: 09524 - Berkeley -09524				
2022-3900485	04/18/2022	8401 Airport RD	Mutual aid given	571 - Cover assignment, standby, moveup

Ladue Fire Department


St. Louis, MO

This report was generated on 5/11/2022 7:45:46 AM



Count of Aid Given and Received for Incidents for Date Range

Start Date: 04/01/2022 | End Date: 04/30/2022



AID TYPE	TOTAL	% of TOTAL
Mutual aid received	8	6.0%
Automatic aid received	5	3.7%
Mutual aid given	28	20.9%
Automatic aid given	21	15.7%
None	72	53.7%

Only REVIEWED incidents included



emergencyreporting.com

Doc Id: 549

Page # 1 of 1